

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No.

27/2E-9J
037119

Water Right Permit No.

(1) OWNER: Name J.A. Schwager Address _____

(2) LOCATION OF WELL: County ISLAND NE SE Sec 9 T 29 N. R 2E W.M.

(2a) STREET ADDRESS OF WELL (or nearest address) S. Bush Pt Rd

(3) PROPOSED USE: ☒ Domestic ☐ Industrial ☐ Municipal ☐
☐ Irrigation ☐ Test Well ☐ Other ☐
☐ DeWater

(4) TYPE OF WORK: Owner's number of well (if more than one) 4
Abandoned ☐ New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☒ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 149 feet. Depth of completed well 149 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 " Diam. from 0 ft. to 139 ft.
Welded ☒ " Diam. from _____ ft. to _____ ft.
Liner installed ☐ " Diam. from _____ ft. to _____ ft.
Threaded ☐ " Diam. from _____ ft. to _____ ft.

Perforations: Yes ☐ No ☒

Type of perforator used _____

SIZE of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

Screens: Yes ☒ No ☐

Manufacturer's Name Johnson

Type STAINLESS, WELDED Model No. _____

Diam. 6 Slot size 12 from 139 ft. to 144 ft.

Diam. 6 Slot size 12 from 144 ft. to 149 ft.

Gravel packed: Yes ☐ No ☒ Size of gravel _____

Gravel placed from _____ ft. to _____ ft.

Surface seal: Yes ☒ No ☐ To what depth? 18" ft.

Material used in seal BENTONITE

Did any strata contain unusable water? Yes ☐ No ☒

Type of water? _____ Depth of strata _____

Method of sealing strata off _____

(7) PUMP: Manufacturer's Name _____

Type: _____ H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level 120' ft.

Static level 60' ft. below top of well Date July 90

Artesian pressure _____ lbs. per square inch Date _____

Artesian water is controlled by _____ (Cap. valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☐ No ☐ If yes, by whom? _____

Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.

" " " " " "

" " " " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time Water Level Time Water Level Time Water Level

Date of test _____

Bailer test 20 gal./min. with 35 ft. drawdown after 2 hrs.

Airtest _____ gal./min. with stem set at _____ ft. for _____ hrs.

Artesian flow _____ g.p.m. Date _____

Temperature of water _____ Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
HARD PAN	2	22
SANDY CLAY	22	130
FINE WATER SAND	130	139
WATER SAND	139	149
CLAY CHUNKS	149	

JUL 26 1990

DEPT. OF ECOLOGY

Work started July, 19. Completed July, 19 90

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME WHIDBEY DRILLERS
(PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)

Address PAK HARBOR 98277

(Signed) Pam John License No. 129
(WELL DRILLER)

Contractor's Registration No. WHD 289 MM Date July, 19 90

(USE ADDITIONAL SHEETS IF NECESSARY)